

STATE OF HAWAII
DEPARTMENT OF HEALTH

PUBLIC SWIMMING POOL INSPECTION REPORT

DATE: 6/2/21

Page 1 of 1

NAME OF FACILITY/COMPLEX (Hotel, Condominium, Apartment, Townhouse, Recreation Center, School, Amusement Park, Etc.):

Nanawale Longhouse

POOLS SHARING THE SAME DISINFECTION SYSTEM MAY BE LISTED UNDER ONE PERMIT. LIST POOLS:

- 1) Nanawale Swimming Pool 4) _____
 2) _____ 5) _____
 3) _____ 6) _____

LOCATION ADDRESS: 14-855 Kehau Rd. TIME START: 9:55AM TIME END: 10:30AM

OWNER NAME: Nanawale Community Association, Inc. POOL OPERATOR: Stephan Becker

PERMIT NO.: HSP0011 POOL TYPE: (circle one) FRESH WATER SALT WATER INSP TYPE: (circle one) REGULAR FOLLOWUP CONSULTATION **COMPLAINT** COMPLAINT FOLLOWUP OTHER

SECTION 11-10-3: PLAN REVIEW; FEE

1. Plans and specifications submitted; approved; fee paid

SECTION 11-10-4: PERMIT; FEE

2. Swimming pool(s) permitted; fee paid

SECTION 11-10-15: FRESHWATER SWIMMING POOLS

3. Water supply approved, supplied through air gap or approved means
 4. Water system piped to prevent cross-contamination, backflow
 ✓ 5. pH between 7.2 and 7.8
 ✓ 6. Chlorine disinfection level minimum 0.6 ppm
 ✓ Other disinfection chemicals registered with EPA, residual at approved level
 ✓ 7. Other chemicals used for water quality safe, approved
 ✓ 8. Water clarity sufficient at all times

SECTION 11-10-16: SALTWATER SPECIALTY SWIMMING POOLS

9. Water clarity sufficient at all times, monitored daily at peak use
 10. Bacteriological samples satisfactory
 11. Closed system disinfected. Open system circulated once every 6 hours
 12. No hazardous marine life in pool
 13. Monitoring plan, quality control/quality assurance plan, and maintenance and management plan submitted, approved
 14. Water exchange monitored daily
 15. Placard posted if pool not disinfected

SECTION 11-10-17: WASTEWATER DISPOSAL

16. Backwash water disposed in an approved manner
 17. Bathhouse sewage disposed in an approved manner
 18. Drained pool water free of chlorine

SECTION 11-10-18: CLEANING

- ✓ 19. Pool free from scum, dirt, silt, organic matter, cleaned within 24 hours
 20. Pool, deck, locker room, bathroom surfaces clean, easily cleanable

SECTION 11-10-19: BATHHOUSES (where applicable)

21. Dressing and sanitary facilities provided
 22. Rooms clean, lighted, ventilated, drained, maintained, impervious material
 23. Separate facilities for male and female
 24. Partitions, floors properly constructed
 25. Drinking fountain provided

SECTION 11-10-20: TOILETS AND SHOWERS (where applicable)

26. Minimum sanitary facilities provided
 27. Soap and toilet paper provided

SECTION 11-10-21: RECORDS

28. Proper pool records kept daily, on file for 12 months

SECTION 11-10-22: RULES

29. Pool rules enforced, placard properly displayed

The item(s) listed below identify violation(s) of Hawaii Administrative Rules, Title 11, Chapter 10, "Public Swimming Pools". Failure to correct the violation(s) by the specified date(s) may lead to enforcement action.

ITEM#	DESCRIPTION OF VIOLATION	CORRECT BY
	No Violations cited, Complaint Abated	

ITEM NUMBERS CORRECTED:

REMARKS Complaint: Check swimming pool chemical levels as its burning complainant's eyes. Also algae present in the pool.

pH: 7.2 Water clarity ok, no algae observed
 Free Cl 2.2 ppm Records okay, clarity water

Pool Time Chlorinated Tabs, Dry Tee Calcium Hypochlorite, Sodium Bicarbonate

RECEIVED BY Amy Barnett TITLE GM SANITARIAN Jeff Mukai R.S. # _____

Sanitation Branch 591 Ala Moana Boulevard Honolulu, HI 96813 586-8000 FAX: 586-8040
 Hawaii District Health Office/Hilo 1582 Kamehameha Avenue Hilo, HI 96720 933-0917 FAX: 933-0400
 Hawaii District Health Office/Kona 81-980 Helekii Street, Suite 103 Kealahou, HI 96750 322-1507 FAX: 322-1511
 Maui District Health Office 54 High Street Room 300 Wailuku, HI 96793 984-8230 FAX: 984-8237
 Kauai District Health Office 3040 Umi Street Lihue, HI 96766 241-3323 FAX: 241-3566